

VENTILATION:

- 1. All ventilation to comply with Building Regs. AD F1 to all areas, inc. any existing areas.
- 2. Public areas adapted/retained to give 15 a/c per hour.
- 3. Internal toilet lobbies to be mechanically vented. Allow 3 air changes/hour with 15 min. overrun.
- 4. Kitchen ventilation to be capable of 40 a/c per hour.
- 5. Mechanical ventilation to be provided to new office / staff areas with adequate intake air.

CCTV:



















- 1. CCTV to be installed to meet any requirements of the police and/or liquor licensing authorities.

job title

THE MALTINGS_
9 CLAYPATH LANE
SOUTH SHIELDS
NE33 4PG

| | |
|----------|---|
| drg. no. | |
| 09 | A |

FIRE PRECAUTIONS LEGEND

| | | | |
|---|---|---|--|
|  | ELECTRONIC FIRE ALARM SOUNDER |  | EMERGENCY LUMINAIRE MAINTAINED |
|  | FIRE EXTINGUISHER - FOAM |  | EMERGENCY LUMINAIRE NON-MAINTAINED |
|  | FIRE EXTINGUISHER - DRY POWDER |  | CALL POINT |
|  | AFFT MULTIPURPOSE EXTINGUISHER 5.5 LITRE BS5423 ELECTRICALLY NON CONDUCTIVE 13A + 113B RATING |  | FIRE ALARM PANEL |
|  | FIRE EXTINGUISHER - CO2 |  | FIXED HEAT RATE- RISE DETECTOR |
|  | FIRE EXTINGUISHER - WATER |  | HEAT FIXED TEMP FT |
|  | FIRE BLANKET |  | FD 60S 1 HOUR FIRE DOOR WITH SMOKE SEALS |
|  | HEAT RATE RISER RR |  | FD 30S 1/2 HOUR FIRE DOOR WITH SMOKE SEALS |
|  | SMOKE DETECTOR | | SOUND SYSTEM TO HAVE RELAY ON FIRE ALARM |
|  | EMERGENCY EXIT LUMINAIRE | | NOTE : ELECTRICAL CONTRACTOR TO LIAISE WITH DESIGNER REGARDING FINAL POSITIONS OF ALL EMERGENCY DETECTION EQUIPMENT INCLUDING EMERGENCY LIGHTING PRIOR TO FINAL INSTALLATION |

(RUNNING MAN SHOWN INDICATIVELY AND DOES NOT NECESSARILY INDICATE DIRECTION OF ESCAPE FOR PURPOSE OF THE LEGEND - ELECTRICAL CONTRACTOR TO LIAISE WITH DESIGNER)