Conversion of three bedroom mid terrace property to form Sui Generis 7 bed HMO for up to 10 persons in 7 households (7 singles, or 4 singles and 3 couples). Loft conversion and installation of 3no. roof windows to rear roof slope. Single storey extension to rear. Removal of existing rear projection.
At 78 Hedworth Lane, Boldon Colliery, NE35 9HZ

Category Sui Generis – Houses in Multiple Occupation
This type of HMO is rented to a group of people on individual contract
like professionals working locally.
Occupiers can have exclusive use of a bedroom with en-suite bathroom and would share two of cooking and dining facilities. Bedrooms are big enough to have dining space inside.

Heating
Fixed heating is to be provided throughout the property which is capable of efficiently maintaining an indoor temperature of 21ºC in all habitable rooms and bathrooms and 18ºC in all functioning space (hallways, corridors and passages) when the outside temperature is -1ºC. The provision of insulation can assist in meeting this standard.
•Gas central Heating
•Electric storage heaters Economy 7

Insulation
The level of insulation which is appropriate will vary according to the differences between gas/oil heating systems and the other systems listed above. It is recommended that 270mm of loft insulation is provided.
If the existing loft insulation has settled or is less than 100mm in thickness, it should be topped up.
Un-insulated cavity walls should be insulated to satisfy current building standards

Electricity supply
Electrical socket outlets shall be provided to individual rooms to a minimum standard
•Living rooms – 4 single sockets (or 2 double sockets).
•Bedrooms – 4 single sockets (or 2 double sockets).
•Bedrooms containing living space – 6 single sockets (or 3 double sockets).

Natural lighting
All habitable rooms should be capable of direct illumination by natural light sufficient to allow normal daytime activity without the need for additional artificial lighting. Total glazed area should be equivalent to at least 1/10th of the floor area and is to be provided with a direct view to the outside environment. (Light tubes are not acceptable).
All kitchens, bathrooms and water closet compartments shall ideally comply with requirements above. All glazing to windows in bathrooms and water closet compartments is to be obscure. Where it is not practicable to provide natural light, adequate artificial lighting shall be provided.

Artificial lighting
All rooms, passageways, staircases and cellars in use shall be adequately lit with suitable switching, including two-way switching to stairs and passageways etc., as necessary.
There should be sufficient switches to operate the lighting on each staircase, landing, corridor or passage and each switch should allow adequate lengths of corridors, passages and stairways to be illuminated at the same time. Time switches will only be allowed on common landings and stairways and should stay on for a sufficient time to allow a person to climb stairs and enter a room.

Ventilation
All habitable rooms with natural ventilation through a window to external air, the openable area of which is approximately 1/20th of the floor area of that room, will be satisfactory for room ventilation. Alternatively, a suitable artificial ventilation system may be provided in accommodation where non-opening windows are required.
In addition to the above, all kitchens and bathrooms will be fitted with mechanical ventilation, with an overrun device in the bathroom, providing a minimum of 3 air changes an hour.

Security of residents
External doors should be provided with appropriate locks, which should be capable of being opened from the inside without the use of the key, to allow residents to escape in case of emergency. To prevent intruders reaching locks by breaking a pane of glass in or near the door, locks should be fitted away from glazed areas. As an additional safeguard Georgian wired glass or strengthened glass should be used in and around doors.
Windows which are accessible from ground level should be provided with security locks, to which the occupant has a key, except where the window is a designated means of escape, in which case it must be capable of being opened from the inside without the use of a key.
Doors to individual lets within the building should also be capable of being opened from the inside without the use of a key.
Bathrooms and toilets should have locks or privacy bolts.

Amenity provision in relation to total number of persons in HMO
6–10 occupants (persons)
•2 bathrooms, AND
•2 separate WCs with WHBs (one of the WCs can be contained within one bathroom)
in this project there is 7 toilets, 7 basins, and 4 shower and 3 baths with shower

All WCs must be properly connected to the drainage system via a trapped waste outlet.
All bathrooms must be suitably and adequately heated and ventilated
All bathrooms and WCs must be of an adequate size and layout.
Baths and WHBs must have a 300mm waterproof splash back.
Showers must have an impervious surround – either a cubicle or filed walls and a screen.
The walls and floor coverings of any bathroom or WC must be reasonably smooth and impervious and capable of being readily cleansed.
Lights must be operated by pull cord switches within bathrooms and WCs.
•Wash hand basins to be not less than 400mm x 300mm (if in separate WC 250mm x 350).
•Baths to be not less than 1700mm in length and 700mm wide.
•Shower trays to be not less than 750mm x 750mm.

Amenity Standards for Kitchen Facilities
Shared kitchens
The following guidance applies when units of accommodation do not contain any facilities for the cooking of food.
•1 cooker with 4 rings/hotplates, a standard size oven and a grill - per 5 persons. Microwave ovens may be satisfactory as a supplementary cooking appliance in place of 2 rings/hotplates.
Where a bedsit type HMO is occupied by up to 7 persons the standard may be met by providing a microwave in addition or a cooker with 6 rings and more than one oven.
•1 sink, of minimum dimensions 500mm x 600mm, with drainer per 5 persons. Sinks must be supplied with a constant supply of hot and safe stable cold water and be properly connected to the drainage system via a suitable trap.
Where 6 to 10 persons occupy a house, the provision of a double-bowled sink & single drainer (a dishwasher is acceptable as a second sink), may be treated as meeting this standard.
•4 sockets (2 doubles) per 3 persons plus an additional double socket for each additional household sharing the kitchen up to a maximum requirement of 4 doubles. Electrical appliances
The electrical wiring and installation should be tested and certified by an NICEIC or ECA registered electrical contractor and the appropriate certification provided every five years or at change of tenancy if appropriate. All Code 1 & 2 defects should be attended to as a matter of priority

There should be sufficient and suitably located socket outlets to avoid overloading the supply and the use of multiple adaptors. There should be no electrical sockets in bathrooms, near kitchen sinks, wash hand basins or other sources of water. Ceiling switches should operate electric light fittings in bathrooms.
All electrical equipment must be supplied in a safe and fully operational condition with appropriate fuses and plugs. There should be no taped joints or loose or exposed wiring.

•work top 500mm x 1000mm per 3 persons with an additional 250mm for every additional person sharing the kitchen to a maximum requirement of 2000mm.
•1 standard 500mm wide base or wall unit plus 30 litres of refrigerated storage space per person. Adequate freezer space is also required.
•provided extractor fan which is capable of achieving 3 air changes an hour.
•provided fire blanket which is capable of achieving 3air changes an hour.

BEDROOMS
Bedroom size With NO Communal (Lounge) Area
One Person - Single Bedroom 6.51m² (Bedroom 13m² - kitchen facilities within unit)
Two persons living as a co-habiting couple/single house hold -
Double Bedroom 10.22m² – unit not containing kitchen facilities

KITCHEN
Where communal dining or living rooms are provided
They must be separate from any kitchen, and each other and be:
•For up to 6 persons the kitchen or kitchen area should be a usable floor area (measured wall to wall, including space occupied by units/cabinets) of at least 7.0 m²

•An additional 1m² per person is required if residents are expected to use dining facilities in the kitchen. Optimal floor space for kitchens is dependent on suitable design and layout. Please note larger floor space may be required to fit in all required facilities.

Fire precautions
Appropriate fire precautions and equipment (e.g. alarms/sounders/detectors, extinguishers) must be provided of such type, number and location as is considered necessary. Such facilities must comply with BS5839, Part 6.
All fire detection, equipment and emergency lighting must be routinely tested and serviced to maintain in full working order.
Landlords or managing agents of HMOs, as 'responsible persons', have a duty to take general fire precautions to ensure, as far as is reasonably practicable, the safety of people on the premises and in the immediate vicinity. For this purpose a Fire Risk Assessment should be carried out in order to:

•identify fire hazards
•reduce the risk of those hazards causing harm to as low as reasonably practicable; and
•decide what physical fire precautions and management arrangements are necessary to ensure the safety of people in the property if a fire does start.

•Grade A: LD2 coverage – mains powered detection in all circulation spaces that form part of the escape route and heat detectors within the bedsit. These must all be interlinked.
A Fire Risk Assessment is an organized and methodical look at the premises, the activities carried on there and the likelihood that a fire could start and cause harm to those in and around the premises.
Advice in relation to fire safety can be found in the LACORS guidance document: 'Housing – Fire Safety – Guidance on fire safety provisions for certain types of existing housing', which describes appropriate measures for fire safety that may be required in a range of housing situations, including HMOs. This document also sets out when and how to carry out a Fire Risk Assessment.

Regulation
Provide details, (ideally a notice board) in the entrance hallway or Lounge/lobby with the following information:
- Name , address & contact number of the property manager.
- Fire escape plans of the property.
- A copy of mandatory licence required to the property (HMO, Gas Safety Cert, Domestic Electricity installation report, EPC, Fire Detection & Alarm System , Emergency light inspection,, L/L liability insurance)
Provide and fit appropriate notices to the wall of the means of escape and fire exits(as on Fire risk assessment)

INTERNAL Partition walls
Knauf metal solution Sections
Knauf CW = and CW Studs C shaped profiles friction fit at equal distances into the head and base UW channels to form the vertical metal stud frame. Knauf UW Tracks U-shaped profiles used for forming the floor and ceiling perimeter frame in drywall partitions.
Knauf Deep Flange UW Tracks U-Shaped profiles used to ceiling perimeter form where high deflection tolerance is required.
Knauf UD 28/27 Channels U-Shaped channels used for perimeter framing for Knauf W623 wall lining systems.
Knauf CD 60/27 and CD50/27 Channels C-shaped channels used for vertical framing in Knauf W623 Wall Lining Systems.
Partitions Wall Linings / Furrings. with head & sole plates and noggins at max 600mm, with Rockwool insulation, ¼ Soundboard + skim plaster finish

Optional
(INTERNAL STUD PARTITIONS)
75mm x 38mm softwood treated timbers studs at max 400mm ctrs with 38x75mm head and sole plates and solid intermediate horizontal noggins at 1/3 height or 450mm. Provide min 10kg/m³ density acoustic soundproof quilt tightly packed (e.g. 100mm Rockwool or Isowool mineral fibre sound insulation) in all voids the full depth of the stud. Partitions built off doubled up joists where partitions run parallel or provide noggins where at right angles, or built off DPC on thickened concrete slab if solid ground floor. Walls faced throughout with 2x 12.5mm plaster board with skim plaster finish. Taped and jointed complete with beads and stops.

DOORS & WINDOWS (FIRE DOORS)
If the dwelling has a protected route for means of escape or is a 2or3 storey house new doors on to the hallway are to be FD30 half hour fire doors.
900 door sets to give 850 min cellar opening width. to give 2m² floor area vent. double glazing to give max value 1.8 W/m2oC.
FD20– 20 minute fire Resisting door and frame.
Front door 900 door sets to give 800 min cellar opening width.
FD30– 30 minute fire resisting door and frame.
PVC windows to give 2m² floor area vent, double glazing to give max u value 1.8 W/m2oC.
Window to have unobstructed opening 0.33m² min and 450 min wild above floor.
Roof windows – 30 minute fire resisting and fire evacuation exit.

UPGRADING EXISTING SINGLE SKIN PARTY WALL
The existing walls must be checked for stability and be free from defects as required by the Building Control Officer. Provide a scratch coat render to existing wall. Construct an independent studwork lining using 100mm x 50mm treated timbers with head & sole plates and noggins at 400mm centres, leaving a gap of 15mm between the wall and the inner face of the studwork to ensure that airborne sound transmission is reduced. Seal the perimeter of the with tape or sealant. Wall to be lined with 30mm total thickness of plasterboard (minimum 20kg/m³) with staggered joints and with at least 35mm of mineral wool quilt density 10kg/m³ between studs. Finish with 3mm plaster skim.

NOTICES AND SIGNS (in accordance to Fire risk assessment and Fire Escape Plans)
All fire safety signs, notices and graphical symbols should conform as far as practicable with BS 5499 Part 1: Specification for Fire Safety Signs, where applicable BS 2560: Specification for Exit Signs (internally illuminated) and Health and Safety (Signs and Signals) Regulations (NI) 1996. Existing signs and notices need not be replaced immediately if they are fulfilling their purpose effectively. They should, however, be examined and be replaced if they are found to be inadequate.
A door fitted with a panic bolt or panic latch should have the words "Push Bar To Open" in conspicuous lettering of appropri- ate size printed on the door immediately above the push-bar.
A sign with the words "Fire Door–Keep Shut" should be perma- nently displayed at about eye level on both faces of all fire doors except doors which are kept open and which close automatically on the operation of fire sensors. Doors of the latter kind should be marked in lettering of appropriate size "Automatic Fire Door - Keep Clear"–"Close at Night" as appropri- ate. "Fire Door" signs need not be displayed on the entrance doors to each individual occupied room in category A, B or D or on the doors to or within self-contained units (category F).
A sign with the words "Fire Door - Keep Locked" should be permanently displayed on the outside of all fire doors to cupboards and boiler rooms.
A sign with the words "Fire Escape – Keep Clear" should be permanently displayed at about eye level on each face of all doors which are provided solely as means of escape in case of fire and which, because they are not normally used, are liable to be obstructed. This is particularly relevant in the case of communicating or by-pass doors used as fire exits which pass through habitable rooms.

EXTRACT TO BATHROOM
Bathroom to have mechanical vent ducted to external air to provide min 15 litres / sec extraction. Vent to be connected to light switch and to have 15 minute over run if no window in room. Internal doors should be provided with a 10mm gap below the door to aid air circulation.
Ventilation provision in accordance with the Domestic ventilation compliance guide. Intermittent extract fans to BS EN 13141-4. All fixed mechanical ventilation systems, where they can be tested and adjusted, shall be commissioned and a commissioning notice given to the Building Control Body

UPGRADE OF EXISTING FLOOR WITH AN INDEPENDENT CEILING
(As detailed in Approved Document E3)
The existing floor should be assessed to ensure any additional loads imposed on it can be carried safely or be strengthened where necessary. Any required remedial works to be undertaken before
the floor treatment is provided. If the floor boards are considered unsuitable for upgrade the floor boards are to be replaced with boarding of a minimum thickness of 12mm. Gaps in the timber boarding
should be sealed by overlaying with hardboard or filled with sealant.
Upgrade existing ceiling by providing 2 layers of plasterboard under existing ceiling with a total mass per unit area 20kg/m² with staggered joints.
New independent ceiling
Construct a new independent ceiling under existing ceiling using C24 timber joists (sizes to structural engineer's details) fixed to the surrounding wall only; ensure a minimum clearance of 25mm is
provided between the top of the independent ceiling joists and the underside of the existing floor (additional support can be provided using resilient hangers attached directly to the existing floor
base if required).
Lay 100mm mineral wool with a minimum density 10kg/m³ between the joists and provide 2 layers of plasterboard minimum total mass per unit area 20kg/m² under new ceiling with staggered joints. The
top of the independent ceiling to be at least 125mm from the underside of the existing floor. Seal the perimeter of the independent ceiling with tape or sealant.

DEMOLITION / TEMPORARY WORKS
All temporary works are to be designed by main contractor. All temporary works designs are to take account of propping loads shown on the plan and
also any lateral eorces that may affect the stability of the structure during demolition. The contractor should submit a risk assessment and method statement in accordance with the CDM regulations for the approval of the planning supervisor.
Priory to any demolition works taking place the main contractor is to identify the following:
1. The presence of any underground culverts.
2. Any underground and overhead services (water, electric, gas and sewerage).
3. The location of any underground cellars or storage tanks

Bedroom no.1 - Ground floor front 15.50m² (Bedroom/Living Room)
- Supply and fit a smoke detector linked in with existing system
- Supply brush strips (smoke block) to door / frame
- Supply and fit a thumb turn lock
- Supply and fit a door closer with 2 way adjustment (optional)
- Supply and fit window coverings – either nets and curtains or vertical blinds
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Ensure two double sockets
- Provide laminate flooring (Impact resistance >8N/ = 500mm R8) Fire resistance EN 13501-1

Bathroom no1 – en-suite 2.91m²
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Provide tiles flooring
- Ensure shower screen is in good condition and save
- Provided mechanical ventilation

Bedroom no.2 - Ground floor front 14.04m² (Bedroom/Living Room)
- Supply and fit a smoke detector linked in with existing system
- Supply brush strips (smoke block) to door / frame
- Supply and fit a thumb turn lock
- Supply and fit a door closer with 2 way adjustment (optional)
- Supply and fit window coverings – either nets and curtains or vertical blinds
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Ensure two double sockets
- Provide laminate flooring (Impact resistance >8N/ = 500mm R8) Fire resistance EN 13501-1

Bathroom no2 – en-suite 2.91m²
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Provide tiles flooring
- Ensure shower screen is in good condition and save
- Provided mechanical ventilation

Bedroom no.3 - Ground floor front 11.06m² (Bedroom/Living Room)
- Supply and fit a smoke detector linked in with existing system
- Supply brush strips (smoke block) to door / frame
- Supply and fit a thumb turn lock
- Supply and fit a door closer with 2 way adjustment (optional)
- Supply and fit window coverings – either nets and curtains or vertical blinds
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Ensure two double sockets
- Provide laminate flooring (Impact resistance >8N/ = 500mm R8) Fire resistance EN 13501-1
- Check sub-floor boards, use sound proof insulation to upgrade if needed

Bathroom no3 – en-suite 2.63m²
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Provide tiles flooring
- Ensure shower screen is in good condition and save
- Provided mechanical ventilation

Bedroom no.4 - First floor front 15.00m² (Bedroom/Living Room)
- Supply and fit a smoke detector linked in with existing system
- Supply brush strips (smoke block) to door / frame
- Supply and fit a thumb turn lock
- Supply and fit a door closer with 2 way adjustment (optional)
- Supply and fit window coverings – either nets and curtains or vertical blinds
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Ensure two double sockets
- Provide laminate flooring (Impact resistance >8N/ = 500mm R8) Fire resistance EN 13501-1

Bathroom no4 – en-suite 2.94m²
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Provide tiles flooring
- Ensure shower screen is in good condition and save
- Provided mechanical ventilation

Bedroom no.5 - First floor front 14.00 m² (Bedroom/Living Room)
- Supply and fit a smoke detector linked in with existing system
- Supply brush strips (smoke block) to door / frame
- Supply and fit a thumb turn lock
- Supply and fit a door closer with 2 way adjustment (optional)
- Supply and fit window coverings – either nets and curtains or vertical blinds
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Ensure two double sockets
- Provide laminate flooring (Impact resistance >8N/ = 500mm R8) Fire resistance EN 13501-1

Bathroom no5 – en-suite 2.54m²
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Provide tiles flooring
- Ensure shower screen is in good condition and save
- Provided mechanical ventilation

Bedroom no.6 - First floor front 8.70 m² (Bedroom/Living Room)
- Supply and fit a smoke detector linked in with existing system
- Supply brush strips (smoke block) to door / frame
- Supply and fit a thumb turn lock
- Supply and fit a door closer with 2 way adjustment (optional)
- Supply and fit window coverings – either nets and curtains or vertical blinds
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Ensure two double sockets
- Provide laminate flooring (Impact resistance >8N/ = 500mm R8) Fire resistance EN 13501-1

Bathroom no6 – en-suite 4.20m²
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Provide tiles flooring
- Ensure shower screen is in good condition and save
- Provided mechanical ventilation


Bedroom no.7 - Second floor front 18.45 m² under 1.5 m high (Bedroom/Living Room)
- Supply and fit a smoke detector linked in with existing system
- Supply brush strips (smoke block) to door / frame
- Supply and fit a thumb turn lock
- Supply and fit a door closer with 2 way adjustment (optional)
- Supply and fit window coverings – either nets and curtains or vertical blinds
- Ensure a TRV is fitted to the radiator
- Decorate walls and gloss-woodwork
- Provide tiles flooring
- Ensure shower screen is in good condition and save
- Provided mechanical ventilation

Ground floor Kitchen/Dining 16.36m² shared area
Second floor Kitchen 3.30m² shared area


- Supply & fit CO detector – if gas cooker is fitted and boiler present
- All kitchen cupboards to be clean in good order with doors that open and close properly
- Work-tops to be in good order and secure
- Ensure there are three double sockets fitted above the work-top
- Silicone seal floor edges including up to the plinths
- Seal work-top at back against tiles
- Seal around edges of sinks with silicon seal
- Humidistat Fan(s) or cooker Hoods to be provided and the air ducted out of the kitchen
- Supply and fit TRV to the radiator
- Decorate fully including gloss woodwork
- Supply a dining table with chairs (min3) DINING ROOM
- Supply and fit wall units (if needed)
- Supply vertical blinds
- Supply a microwave – HMO requirements for 6 users (option)
- Supply a washing machine
- Supply an adequate refrigerator space, (a minimum capacity of 0.03 m³/ 111 per individual), together with storage space for frozen foods; 7 individual undercounted fridge freezer 87 liters each
- There is a work-top for the preparation of food that has not less than 2000mm x 600mm available space per 5 persons within the kitchen, with adequate power sockets.
- One cooker to be provided for every five occupants. The main cooker should have three or four rings or hot plates together with a grill and oven. Combination Microwaves are acceptable as secondary appliances.
- A clearance of at least 300mm from any pan handles or hot surfaces is required – this is particularly important in small galley kitchens
- A sink should be provided for every five occupants.
- Sinks should be complete with drainer and provided with supplies of constantly available hot and cold running water.
- Dishwashers are acceptable as secondary appliances.
- When food is cooked, and prepared for residents as part of their board payment, all catering facilities shall comply with the requirements of the current Food Hygiene Regulations.

Existing floor plan


ground floor plan




first floor plan




cross view




Current yard






Front view existing




Rear view existing

Planned floor plan


ground floor plan




first floor plan




second floor plan




cross view




Extension footprint






Front view



Rear view with extension


Rear elevation changes:
- removing small rear extension
- install 3 attic velux windows
- build 24.8 m2 rear extension with 2 roof windows and doors from yard side only




Rear view of extension

Planned floor plan


ground floor plan




first floor plan



second floor plan




cross view



NOTICES AND SIGNS – All fire safety signs, notices and graphical symbols should conform as far as practicable with BS 5499 Part 1: Specification for Fire Safety Signs, where applicable BS 2560: Specification for Exit Signs (internally illuminated) and Health and Safety (Signs and Signals) Regulations (NI) 1996.
Existing signs and notices need not be replaced immediately if they are fulfilling their purpose effectively. They should, however, be examined and be replaced if they are found to be inadequate.

FIRE FIGHTING EQUIPMENT - shall be provided in all HMOs. The number and siting of all fire fighting equipment shall be to the satisfaction of the Fire Authority. As a general guideline the following is given as a guide: The provision shall be 1 multi-role fire extinguisher of 13a rating situated on each floor. A fire blanket in each room used for cooking in accordance with BS 6575. A carbon dioxide fire extinguisher adjacent to any electrical equipment. Extinguishers Extinguishers shall be installed and maintained in accordance with BS/EN/DIN/ and BS5306 Part 3 (1985).



Notice: All construction work should be carried out by a competent builder.
•The builder is responsible for all temporary supports and is to ensure that the structure is adequately supported during the works.
•Steel beams are heavy components and may require mechanical lifting aids.
•All work on flashings and masonry is to be re-built.
•Existing foundations are assumed to be adequate, however, this is subject to exposing the existing foundations and an inspection for the satisfaction of the Building Control Officer.
•Steel beam end bearings not to be located above lintels or openings.
•Steel beam end bearings not to clash with or be located near the end bearings of existing beams or existing lintels.
•Steel beam end bearing not to be inserted into a chimney or chimney breast.
•Steel beam end bearings to be located on substantial load bearing masonry walls or piers. Plan area of bonded masonry supporting steel beam to be greater than or equal to 0.1m².
•Supporting masonry to comply with Eurocode 6 or BS 5628.
•Steel beams to be encased in fire-line board to achieve 1/2 hour fire resistance in accordance with manufacturer's recommendations.
•No point loads or concentrated loads are to be applied to the steel beam

Notes:
THIS DRAWING IS TO BE CHECKED & VERIFIED BY THE CONTRACTOR PRIOR TO WORK COMMENCING ON SITE & ANY DISCREPANCY OR QUERY SHALL BE IMMEDIATELY REPORTED & RESOLVED BEFORE PROCEEDING WITH CONSTRUCTION

Drawing Description:	Proposed House in Multiple Occupation conversion Cat. Sui Generis
Site:	78 Hedworth Lane Boldon Colliery NE35 9HZ
Client:	Mr. Artur Dolowski
Date: 25/05/2023	Ref nr: HL/25/05/23
Scale: 1:100 (as noted @A0)	Draw: Artur Dolowski

This design remains copyright to Artur Dolowski. Changes should be queried with the designer. Please check you are working off the most recent version of the plan. It is the responsibility of the crew members to ensure they are installing this rig in accordance with manufacturer's instructions and current regulations. Any discrepancies between the drawings and the site must be strongly recommended to verify all measurements on site. This drawing has been produced for Planning purposes only and should not be used for any other purposes. This drawings may be subject to amendments and/or seeking approvals from Local Authority. Work undertaken prior to consent is done so at client' risk. Any surveyed information incorporated within this drawing cannot be guaranteed as accurate unless confirmed by fixed dimension check

SPACEDIRECT Architectural Planning & Development
www.spacedirect.co.uk