Matthew Alexander

From: Lea Nicholson <Lea.Nicholson@southtyneside.gov.uk>
Sent: 23 March 2021 16:41
To: [redacted]
Subject: RE: west bolden

Hi Habib,

Apologies for the delay in getting back to you, I have spoken with NWL and agreed that 5l/s would be an acceptable discharge rate for this location.

NWL have confirmed the 18.8l/s response is not valid as it was carried out in 2017 and is relating to the original proposal. This is now out of date as it is only valid for 12 months.

If you require further information please contact me.

Regards

Lea

Lea Nicholson
Environmental Protection Officer
Environmental Protection
Development Services
Regeneration and Environment
South Tyneside Council
Tel : 01914247923

From: [redacted] portlandconsulting.co.uk>
Sent: 23 March 2021 08:40
To: Lea Nicholson <Lea.Nicholson@southtyneside.gov.uk>
Subject: west bolden

*** **WARNING** - This message has originated from outside the council. Do not provide any login or password details if requested. Do not click on any links or attachments unless you are sure that the content is safe. If you are unsure about this email or its content forward it to: email.quarantine@southtyneside.gov.uk ***

Hi Lea,

Did you manage to your assessment on the west bolden site mentioned last week?

Could I get a reply back today so I can relay back to the design team.

Any issues, give me a call.

Kind regards,

[redacted]

Portland consulting engineers

10 Bankside, The Watermark, Gateshead, Tyne & Wear, NE11 9SY
T: 0191 461 9770 **DD:** 0191 461 9771
E: habibahmed@portlandconsulting.co.uk **W:** www.portlandconsulting.co.uk

Follow Us:



Think before you print.

1. The information contained in this e-mail and any attachments is intended only for the person or company to whom it is addressed and may contain confidential and/or privileged material.
2. If you receive this email and/or any attachments in error or are not an intended recipient, please contact us at the above telephone number and delete the material from your computer.
3. Portland Consulting Engineers Limited has taken reasonable precautions to minimise the risk of virus infection; however we cannot accept any liability for any loss or damage sustained as a result of software viruses. It is your responsibility to carry out such virus checking as necessary before opening or downloading any attachment into your computer.

Co-operative Council of the Year 2019.

This email and any files transmitted with it are intended solely for the named recipient and may contain sensitive, confidential or protectively marked material up to the central government classification of "RESTRICTED" which must be handled accordingly. If you have received this e-mail in error, please immediately notify the sender by e-mail and delete from your system, unless you are the named recipient (or authorised to receive it for the recipient) you are not permitted to copy, use, store, publish, disseminate or disclose it to anyone else.

E-mail transmission cannot be guaranteed to be secure or error-free as it could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses and therefore the Council accept no liability for any such errors or omissions.

Unless explicitly stated otherwise views or opinions expressed in this email are solely those of the author and do not necessarily represent those of the Council and are not intended to be legally binding.

All Council network traffic and GCSX traffic may be subject to recording and/or monitoring in accordance with relevant legislation.

South Tyneside Council, Town Hall & Civic Offices, Westoe Road, South Shields, Tyne & Wear, NE33 2RL, Tel: 0191 427 7000, Website: www.southtyneside.gov.uk