© Copyright all rights reserved South Tyneside Council, Corporate Development.

IMPORTANT: This building may contain asbestos. No building work should be carried out without first consulting the Asset Management Team (0191 424 7239) for further information.

CONDENSER UNIT LOCATED IN EXTERNAL LIGHTWELL

012	CIRCULATION
	N: 3.79 sqm

103	KITCHEN
	N: 23.95 sqm

REFRIGERANT PIPEWORK CONCEALED WITHIN PLASTIC CONDUIT. CONDUIT TO BE FITTED BELOW ARCHITRAVE. REFRIGERANT PIPEWORK ROUTE THROUGH WC TO EXTERNAL LIGHTWELL

AIR CONDITIONING UNIT

1No LARGE WALL MOUNTED AC UNIT FITTED AT HIGH LEVEL BELOW ARCHITRAVE

011	CCTV ROOM
	N: 67.71 sqm

104	B1 1/001
	N: 75.82 sqm

Rev	Date	Description	Chkd

South Tyneside Council
Chief Executive

Irene Lucas - Chief Executive
Town Hall & Civic Offices, Westoe Road, South Shields, Tyne & Wear, NE33 2RL
Telephone: (0191) 427 1717 Fax: (0191) 455 7770

Project
Jarrow Town Hall
CCTV Works
Listed Building Submission

Drawing Title
First Floor AC Proposal
Option B

Drawn by	PD	Date	27-11-23
Checked by	XX	Date	--/--/--
Scale	1:25	Size	A1

Project Code	Drawing Number
JARROW TH	L(5) 02