







EXISTING (PART) PLAN




EXISTING ELEVATION



EXISTING SECTION VIEW A-A



PROPOSED (PART) PLAN



PROPOSED ELEVATION



DO NOT SCALE EXCEPT FOR PLANNING AND BUILDING REGULATION PURPOSES

GENERAL NOTES

LIGHTING :-
ALL LIGHTING TO BE POSITIONED TO AVOID DIRECT GLARE ON THE EYES OF THE USER AND UNWANTED REFLECTIONS FROM THE SCREEN OR OPERATING FEATURES. GLARE FROM LIGHTING TO BE AVOIDED.
SIGNAGE :-
ALL SIGNAGE TO CONFORM TO BS 8300:2001 SECTIONS 9.2.2 LOCATION & DESIGN OF SIGNS & INFORMATION AND 9.2.3 VISUAL SIGNS.
ALL NEW GLAZING CONFORMS TO BS 6206.
ALL ELECTRICAL WORK CONFORMS TO BS 7671.

IT IS ASSUMED THAT ALL PRELIMINARY WORKS CARRIED OUT / CONTRACTED BY THE SITE OWNER (SHOULD THEY BE REQUIRED BY THE PROJECT) ARE COMPLETED IN ACCORDANCE WITH CURRENT BUILDING REGULATIONS 2010 AND AMENDMENTS THEREAFTER

SITE NOTES

FLOOR CONSTRUCTION: CONCRETE

TTW INSTALL
FORM APERTURE THROUGH EXISTING BRICKWORK WALL AND CLADDING


INSTALL: STEEL APERTURE LINERS, ATM ENCLOSURE, PLINTH, ATM, ELECTRICS - NEW DIS. BOARD (TBC) AND ILLUMINATED SIGNAGE
POSSIBLE EARTH BONDING REQUIRED TO GAS AND WATER SERVICE

NOTE:
- NO ASBESTOS REG. NCRA TO ARRANGE ASBESTOS SURVEY REQUIRED PRIOR TO FURTHER SURVEYS AND INVASIVE WORKS COMMENCING
- ALL PROPOSED ATM INSTALL WORKS MUST ALLOW FOR FULL ATM SERVICE CLEARANCE INC. FULL RACK OUT OF REAR DISPENSERS
- NO ACCESS TO ELECTRICS / DIS. BOARD AT TIME OF SURVEY LARGE FRIDGE BLOCKING ACCESS
- CASH ZONE REQUESTED ILLUMINATED SIGNAGE
- CASH ZONE SECURITY TEAM TO ASSESS THE ATM INSTALL LOCATION DUE TO POOR CONSTRUCTION AND THIN METAL ROOF
- DESTRUCTIVE WALL SURVEY REQUIRED

WORK TO BE CARRIED OUT BY SITE

PROVIDE FULL ACCESS FOR ASBESTOS SURVEY AND ANY ADDITIONAL SITE SURVEYS (LARGE FRIDGE BLOCKING ACCESS TO ELECTRICS / DIS. BOARD)

REMOVE LOOSE STOCK IN ATM INSTALL LOCATION
TEMPORARILY RELOCATE BINS FOR ATM DELIVERY ONLY



SECTION VIEW A-A

SITE ADDRESS SA CONVENIENCE STORE 200 ASHLEY ROAD, SOUTH SHIELDS, NE34 0PQ	TITLE PROPOSED AUTOMATED TELLER MACHINE (ATM) INSTALLATION FOR CASHZONE			04				drawing approval	
				03					
				02					
	DRAWN MAL	DATE 16/05/25	SCALE VARIOUS @A3	01	ATM TYPE CHANGED FROM 6625 ADV BEZEL TO 6625 STD BEZEL DUE TO AVAILABILITY. SIGNAGE AMENDED.	27/06/25	MAL	NAME:-	
	REF/DRG No. E029235	SHEET	REVISION 01	REVISION	DESCRIPTION	DATE	BY	POSITION:-	APPROVED:-
								DATE:-	SIGNED:-



NCR ATLEOS